



Ref No: ICTS/TIFR/RFQ/47/2018-19/ADD-01

Date: 10/10/2018

**ADDENDUM TO ENQUIRY**

The following Addendum is issued to the Enquiry for “Supply, Installation, Testing and Commissioning of Rittal data center racks along with LCP unit” Ref No.: ICTS/TIFR/RFQ/47/2018-19

**As in Enquiry:**

Subject: Enquiry for the Supply, Installation, Testing and Commissioning of Rittal data center racks along with LCP unit

**Read as:**

Subject: Enquiry for the Supply, Installation, Testing and Commissioning of additional Rittal data center racks along with LCP unit or equivalent (Datacenter expansion works)

**Scope of Work:**

The bidder has to configure and install the quoted racks to the existing data center infrastructure which consists of 10 racks and 6 LCP units. Out of 10 racks, 2 racks are dummy which need to be converted to smart racks. The quoted 1 no. LCP (In-rack Cooling unit) should be configured to cater to the 4 racks (2 new and 2 old racks)

All vendors participating in this tender must visit the ICTS site at Shivakote for site survey and also meet with the ICTS IT team for detailed discussions and clarifications.

All other terms and conditions of the Enquiry remain unaltered.

**For and on behalf of International Centre for Theoretical Sciences-TIFR**

**Authorized Signatory**

**Administrative Officer - 'C'**  
**International Centre for Theoretical Sciences**  
**Tata Institute of Fundamental Research**  
Survey No. 151, Shivakote,  
Hessarghatta Hobli, Bangalore - 560 089.