

Prebid Queries & Clarifications

Tender for Supply, Installation, Testing and Commissioning of Landscape lighting fixtures including all types of Accessories

02.02.2017 at 11.00 AM

Attended by:

Mr. Sunil Alex, M/s Neycer Electrical Private Ltd
Mr. Shivu, M/s Neycer Electrical Private Ltd
Mr. Hareesh Ambiga, M/s Hareesh Engineering Services Ltd
Mr. Virupaksha, M/s Vedaprakash Associates

Vendor submitted the queries online:

M/s R.K.Associates
M/s. Neycer Electricals

Mr BNR Prasanna, DCSEM
Mr. Mohan Gowda, ICTS
Mr. Amresh Kumar Singh ICTS
Mrs. Rajalakshmi Swaminathan, ICTS

Sl No.	Queries	Clarifications
1	Only one make of light fitting is given in the tender. Equivalent type is not available but equivalent wattage and Lux fitting is available.	Light fittings proposed are: Make: Schreder Model: Hapiled Power: 30 Watt Make: Philips Model: Metronomis LED Version: LED SHARP BDS660 Power: 24-30 watt Specification: The light fixture shall have ULOR less than 5% (IS standard) and low power consumption Luminous flux : 3500-4000
2	Approved make is not having specified wattage given in the tender	You may quote for 30 watt.
3	Can we use same wattage LED fitting of equivalent brand like Wipro, Bajaj, Phillips and K-Lite	You may quote as per model and make specified above.
4	With this ICTS will get best lighting, healthy competition and economical pricing.	You may quote as per specification
5	With only one make we will not get good competition pricing as per CVC guidelines	Quote as per above specification

6	<p>30 watts Hapiled is available instead of 19/28 watts. Please clarify which light fixture we need to considered and also please confirm other make and models.</p>	<p>Light fittings proposed are: Make: Schreder Model: Hapiled Power: 30 Watt</p> <p>Make: Philips Model: Metronomis LED Version: LED SHARP BDS660 Power: 24-30 watt</p> <p>Specification: The light fixture should have ULOR less than 5% (IS standard) and low power consuming. Luminious flux : 3500-4000</p> <p>Quote as per above specification</p>
7	<p>Can we go ahead with other makes for conical poles and also please specify GI or PU painted. We wish to inform GI pole with PU painted is not recommended / available. So for PU painted we need got go with MS pole. Please confirm.</p>	<p>The preferable poles are the Schreder conical pole for Schreder fixtures and Philips pole for Philips fixtures.</p> <p>However other poles can also be considered if the finishing, material quality, technical parameters are met from Schreder and Philips.</p> <p>Poles should have identical arrangements for fixing the approved fittings. Details of the pole manufacturer shall be submitted by 6th Feb 2017 for Departmental approval. The thickness of the PU paint should be as per the manufacturer specification. MS pole PU painted is acceptable. GI tubular is not accepted. (Details of the SOQ is attached).</p>
8	<p>Please Specify the details of RCC Foundation and also specify quantity for extra depth excavation and concrete including excavation backfilling etc.</p>	<p>Submitted as enclosure along with the drawing. Also the revised SOQ is attached.</p>
9	<p>Please confirm can we go ahead with 40 mm HDPE pipe instead of 32mm GI pipe.</p>	<p>Yes 40mm dia HDPE is acceptable. Prior approval of make may be obtained and the specification are as per IS standard.</p>
10	<p>Please confirm payment terms and also regarding Secure advance.</p>	<p>Mobilization advance shall not be payable. Secure advance at 90% of the purchase value of material or derived rate from the quoted rate</p>

		<p>whichever is lower is payable only after delivery of material.</p> <p>No Advance payment.</p> <p>Final bill after the installation, testing and commissioning.</p> <p>10% security deposit for a defect liability period of 6 months.</p> <p>Warranty as per manufacturer.</p>
11	<p>We wish to inform that please consider 60 days for completion instead of 45 days. The lead time for delivery of light fixture is 6 to 8 weeks. Please consider our request.</p>	<p>Works shall be completed in 45 days and the action for procurement shall be initiated immediately after the acceptance of work order.</p> <p>Details of the procurement initiation letter to be submitted to the department.</p>
12	<p>Base plate specification</p>	<p>Appropriate size of base plate will be as per manufacturer specification.</p> <p>In any case it should be approximately 290*290*12 mm</p>
13	<p>Earthing of pole</p>	<p>Earthing of pole on both sides is included in the scope of work.</p>