

# INTERNATIONAL CENTRE FOR THEORETICAL SCIENCES

TATA INSTITUTE OF FUNDAMENTAL RESEARCH

Survey No. 151, Shivakote, Hesaraghatta Hobli, Bengaluru - 560 089

Tel. No : 080 4653 6027, 0,E-mail: purchase@icts.res.in, Website www.icts.res.in

## ENQUIRY

Ref: ICTS/PD/CF22-20/220084

October 25, 2022

Dear Sirs

Please let us have your Quotation for the following:

S.No.	Item Code	Description	Qty	UOM
1	LSWRM000633	<p>Non-Comprehensive Annual Maintenance Contract of centralized Fire Alarm System with the following specification of the equipment:</p> <p>Make Honeywell, Model: ESSER,</p> <p>Single Heat and Smoke Sensor Detector-201 Nos Double Heat and smoke Sensor detector-15 Nos Single Heat and double Smoke Sensor Detector- 18 Nos Manual call point -23 Nos Hooter-23 Nos Repeater panel-3 Nos Main panel -2 Nos</p> <p>Scope of Work: The following are the types of preventive and breakdown services that shall be provided by the Service Provider.</p> <p>Duration: 1 year No. of Visit: 12 (every month) No. of Breakdown: Unlimited</p> <p>1. Service should be carried out monthly under the supervision of the maintenance engineer along with suitable service engineers. 2. Checking the main addressable fire alarm, a panel like incoming supply, motherboard, fuses, LCD display, and keyboard batteries, should be carried out on a monthly basis. All addressable detector cleaning and refixing should be carried out once in six months. 3. To reprogram the Addressable fire alarm panel without any extra charges for any additional device alteration/replacement. 4. To provide a replacement of defective or any spare of the addressable fire alarm system. 5. To attend unlimited breakdown calls within a short time. 6. Monthly visits for preventive maintenance of the equipment's Service report would be made and it is mandatory to submit a report to the Electrical engineer for each visit. 7. Checking the working conditions of all other devices maintenance carried out on a monthly basis is mandatory. 8. Checking of response indication on a monthly basis  </p>	1.00	SET

LSWRM000633 Reinstalling the software if the replacement of equipment is required, as per the instruction of the Engineer In charge

2	LSWRM000634 Add GST @ 18%	1.00	NO
<b>NOTE :</b> 1) DUE DATES FOR SUBMISSION OF QUOTATION AGAINST THIS ENQUIRY IS 15/11/2022 till 15.00 Hours. 2) QUOTATIONS RECEIVED AFTER THE DUE DATE SHALL BE REJECTED. 3) The validity of your quotation should be for 60 days from the date. 4) Your quotation should indicate delivery period & warranty period.			

Quotation sent by hand delivery / courier are to be deposited in the Tender Box kept at the Main Gate after obtaining stamp, date and signature of the Security Officer.

**Quotation should be submitted in sealed envelope duly superscribing our enquiry reference and due date.**

Yours faithfully

  
26/10/22  
(Mr. Abhijit De)

Admn. Officer (Purchase)

Copy to: Prof. / Dr. / Mr. / Mrs. / Ms. / Shri / Smt. CHANDAN KUMAR (ICTS-19P1112)  
Your Indent Req. No. CKR0010090 Dated: 12/10/2022 refers.

Remarks: Non - Comprehensive AMC of Centralized Fire Alarm System of Academic Block, Seminar Block, Utility Block, Security Block of ICTS Campus